J.R.JULIUS, M.E., Ph.D., MIE, FIV,
Civil Engineering Consultant

Phone : 04652 - 261144
Mobile : 94434 14477
98423 14477
email : jrjulius1970@gmail.com

• Plans • Estimates • Valuations • Designs

4A1, St.Antony Street, Thalavaipuram, Nagercoil - 629 004.

S.C. No. 64/2026

Date: 06 03 2026

STATEMENT ACCOMPANYING FORM A

1. Door No. of the building : -
2. Location of the building : The Bharath International School, R.S.No. 1171/12A1B, 1171/13, Rajakkamangalam Village, Koyyanvilai, Rajakkamangalam Village Panchyath, Agastheeswaram Taluk, Kanyakumari District.
3. Year of construction : 2024-2026
4. Approximate cost of constn. as per current rates : 110 Lakhs
5. Purpose for which building is being used/ proposed to be used : School Building
6. Purpose for which building has hither to been used : School building
7. Details of construction of the building
   - Foundation : Isolated R.C.C. Column footing
   - Basement : R.C.C. Plinth Beam & Brick work in C.M.
   - Super Structure : RCC Frame with Brick Wall in CM
   - Floor : PCC & Cement/Vitrified Tile floor finish
   - Roof : R.C.C. slab & beam
8. Period for which license is required : 01-06-2026 to 31-05-2029 (3 years)
9. Number of persons to be accommodated : 500 Nos.

J.R.Julius
District Panel Engineer

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition/alteration is made to the existing building of portion of the building. I also undertake to obtain fresh license, if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.

Signature of the building owner

S.C. No. 64/2026

Date: 06 03 2026

FORM B

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

1.	Depth below ground level	: 3.0 m
2.	Nature of soil met with at foundation level	: Sandy Clay
3.	Pressure at Foundation	: 205.88 KN/m^2
4.	Probable S B Capacity of the strata met with at foundation	: 215 KN/m^2

2. SUPERSTRUCTURE

1.	Maximum stress in the most critical section of masonry and concrete	: RCC 1:1$^1/_2$:3 – 2.12 N/mm^2
2.	Nature of masonry and concrete and its safe permissible stress	: RCC 1:1$^1/_2$:3 – 2.8 N/mm^2

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01-06-2026 to 31-05-2029 (3 years)

J.R.JULIUS Class I A

J.R.Julius
District Panel Engineer

S.C. No. 64/2026

Date: 06 03 2026

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building	Age of the building	The value of the building at the current rates	No. of Stories	Short Description	Certified purpose	Certified Period	No. of persons to be accommodated
The Bharath International School, Koyyanvilai, Rajakkamangalam Village Panchayath, Kanyakumari District.	New Building	110 Lakhs	GF + 1 only	Framed structure with panel wall brick work	School Building	01-06-2026 to 31-03-2029 (3 Years)	500 Nos.

DECLARATION

I, J.R. JULIUS do hereby declare that I possess the qualification and experience stipulated in the table of Rule II of Madras Public Buildings (Licensing) Act for issuing the STRUCTURAL SOUNDNESS CERTIFICATE of the building covered by this certificate.

J.R. JULIUS E1/10012014 Class I A Registered Engineer

J.R.Julius
District Panel Engineer

From
District Collector,
Kanniyakumari District,
at Nagercoil.

To
Thiru. J.R. Julius,
No. 4A1, St. Antony Street,
Thalavaipuram.
Nagercoil – 629004.

E1/8882/14, dated: 23.09.2014

Sir,

Sub : Inclusion of the name of Private Practising Engineer class IA in Kanniyakumari District – informed – Regarding.

Ref : 1. Your application dated: 05.03.14
2. Engineer-in-Chief(Buildings), Chief Engineer(Buildings) Chennai Region, Chief Engineer(Gen) PWD, Chennai Letter No.AEE/T1/AE III/31520/14, dated 11.07.14

It is here by informed that your name has been included in the panel of Private Practising Engineer under class IA (one-A) Category (Buildings, the cost of which exceeds Rupees 50 Lakhs) in Kanniyakumari District as per Engineer-in-Chief(Buildings), Chief Engineer(Buildings) Chennai Region, Chief Engineer(Gen) PWD, Chennai letter in the vide reference 2nd cited.

Sd/- S.Ramachandran,
For Collector,
Special Deputy Collector (SSI)

// True copy // by order //

Head Assistant (E)